



NOTES

1. INCOMERS AND BUSCOUPLERS OF DC MAIN LT PANEL, UPS OUTPUT PANEL, DC PAC PANEL SHALL BE MECHANICALLY INTERLOCKED WITH 3LOCK + 2KEY SYSTEM
2. ALL PANEL S SHALL BE FLOOR MOUNTED.
3. ALL DBS SHALL BE WALL MOUNTED.

MTNL STPI IT SERVICES LTD
 FIRST FLOOR NO:5 RAJIV GANDHI SALAI
 TARAMANI
 CHENNAI 113

TITLE	MAIN SINGLE LINE DIAGRAM	DRAWN	-
PROJECT	MTNL-STPI DATA CENTRE AT CHENNAI	CHECKED	-
CONTRACTOR	-	APPROVED	-

APPROVED BY DG
 ON 12/03/09.
 TO BE TENDERED